



464 Valley Brook Avenue, Lyndhurst NJ 07071
 129 Sea Girt Avenue, Manasquan NJ 08736
 Phone: (800) 423-0766 • Fax: (201) 438-1798
 www.mccabeenv.com

March 28, 2023

Bayonne Board of Education
 669 Avenue A
 Bayonne, New Jersey 07002
 Attn: Mr. Daniel Castles

**RE: District Wide Lead in Drinking Water Testing & Follow-Up Testing
 Summary Letter Report
 MES Project Numbers: 22-04448 & 22-04512**

Dear Mr. Castles:

At the request of Bayonne Board of Education, McCabe Environmental Services, L.L.C. conducted lead in drinking water testing and follow-up testing during the 2022 school year. The following is a summary of samples collected, results, and required follow-up sampling information:

Bayonne Board of Education – Lead In Drinking Water Results Summary		
School	Amount of Samples & Results	Follow-Up Sampling
Bayonne High School	61 Samples – 1 Fail	Failed Outlet was Removed
Bayonne High School Ice Rink	4 Samples – Pass	N/A
Central Food Service Kitchen	4 Samples – Pass	N/A
Henry Harris Community School	34 Samples – 5 Fails	All Failed Outlets Passed Follow-Up Sampling
Horace Mann Community School	17 Samples – 1 Fail	All Failed Outlets Passed Follow-Up Sampling
John M. Bailey Community School	19 Samples – 7 Fails	All Failed Outlets Passed Follow-Up Sampling

Lincoln Community School	30 Samples – 4 Fails	All Failed Outlets Passed Follow-Up Sampling & Other Outlets were Removed
Mary J. Donohoe Community School	25 Samples – 2 Fails	All Failed Outlets Passed Follow-Up Sampling
Nicholas Oresko Community School	13 Samples – Pass	N/A
Philip G. Vroom Community School	21 Samples – 1 Fail	Failed Outlet Passed Follow-up Sampling
Walter F. Robinson Community School	14 Samples – 1 Fail	Failed Outlet Passed Follow-up Sampling
Washington Community School	27 Samples – 1 Fail	Failed Outlet was Removed
William Shemin Midtown Community School	56 Samples – Pass	N/A
Woodrow Wilson Community School	33 Samples – Pass	N/A
<p>Note: All failed water outlets were either removed/taken out of service or passed follow-up sampling.</p>		

Final reports including laboratory analytical results for the initial drinking water testing and follow-up testing have been provided to the Bayonne Board of Education and can be made available upon request.

Thank you for your interest in working with McCabe Environmental Services, L.L.C.

Sincerely,

McCabe Environmental Services, L.L.C.

Gary Clare
Project Manager